



Subject card

Subject name and code	Intelligent Building, PG_00042188						
Field of study	Power Engineering, Power Engineering, Power Engineering, Power Engineering, Power Engineering						
Date of commencement of studies	October 2020	Academic year of realisation of subject			2022/2023		
Education level	first-cycle studies	Subject group			Optional subject group Subject group related to scientific research in the field of study		
Mode of study	Full-time studies	Mode of delivery			at the university		
Year of study	3	Language of instruction			Polish		
Semester of study	6	ECTS credits			2.0		
Learning profile	general academic profile	Assessment form			assessment		
Conducting unit	Department of Electrical Power Engineering -> Faculty of Electrical and Control Engineering						
Name and surname of lecturer (lecturers)	Subject supervisor	prof. dr hab. inż. Stanisław Czapp					
	Teachers	prof. dr hab. inż. Stanisław Czapp dr inż. Krzysztof Dobrzyński dr inż. Tomasz Minkiewicz					
Lesson types and methods of instruction	Lesson type	Lecture	Tutorial	Laboratory	Project	Seminar	SUM
	Number of study hours	15.0	0.0	15.0	0.0	0.0	30
	E-learning hours included: 0.0						
Learning activity and number of study hours	Learning activity	Participation in didactic classes included in study plan		Participation in consultation hours		Self-study	SUM
	Number of study hours	30		3.0		17.0	50
Subject objectives	The achievement of knowledge and skills in the design and commissioning of intelligent electrical installations.						
Learning outcomes	Course outcome	Subject outcome			Method of verification		
	K6_U08	Performs the project of electrical installation and starts this installation in laboratory condition.			[SU4] Assessment of ability to use methods and tools		
	K6_W06	Student interprets topology of KNX/EIB system. Student describes the principles of design of electrical installations with KNX/EIB system. Selects devices for KNX/EIB system and describes their operation.			[SW3] Assessment of knowledge contained in written work and projects		
	K6_U05	Operates expert ETS software.			[SU4] Assessment of ability to use methods and tools		
Subject contents	Definition of intelligent building. Types of control systems in buildings: KNX/EIB, LonWorks, VCN. European Installation Bus KNX/EIB system. The idea of the system, system elements, Sensors and actuators, graphical symbols. Topology. Devices, lines, areas. Physical address, group address. Communication in the KNX/EIB system. Data transmission, telegrams, flags, methods of the access to the bus. ETS software. Design and diagnostics. Design and performance of the KNX/EIB installation. Cables and devices. Overcurrent protection, protection against electric shock, protection against overvoltage. LABORATORY Introduction of ETS software, input data preparation. Principles project performance and starting the system. Electrical lighting switch on and switch off control. Advanced control of lighting (lighting illuminance control, time control). Windows shutter control. Temperature control. Automatic control of illuminance with presence sensor. Integration of systems for advanced topology. Visualization of the installation. Remote monitoring of the installation.						
Prerequisites and co-requisites							
Assessment methods and criteria	Subject passing criteria	Passing threshold			Percentage of the final grade		
	Written exam	50.0%			50.0%		
	Practical exercise	50.0%			50.0%		

Recommended reading	Basic literature	<p>1. Petykiewicz P.: Nowoczesna instalacja elektryczna w inteligentnym budynku. COSiW SEP 2001.</p> <p>2. Mikulik J.: Europejska Magistrała Instalacyjna EIB: rozproszony system sterowania bezpieczeństwem i komfortem. Stowarzyszenie Elektryków Polskich. Centralny Ośrodek Szkolenia i Wydawnictw, Warszawa 2008.</p>
	Supplementary literature	Manual of devices of KNX/EIB system.
	eResources addresses	<p>Adresy na platformie eNauczanie:</p> <p>Budynek inteligentny [EE][2022/23] - Moodle ID: 27164 https://enauczanie.pg.edu.pl/moodle/course/view.php?id=27164</p>
Example issues/ example questions/ tasks being completed	On a laboratory stand, performance of the installation for lighting control (using KNX system).	
Work placement	Not applicable	