

SDAŃSK UNIVERSITY 的 OF TECHNOLOGY

Subject card

Subject name and code	Safety in the use of electrical equipment, PG_00058363							
Field of study	Hydrogen Technologies and Electromobility							
Date of commencement of studies			Academic year of realisation of subject			2025/2026		
Education level			Subject group			Obligatory subject group in the field of study Subject group related to scientific		
						research in the field of study		
Mode of study	Full-time studies		Mode of delivery			at the university		
Year of study	4		Language of instruction			Polish		
Semester of study	7		ECTS credits			4.0		
Learning profile	general academic profile		Assessment form			assessment		
Conducting unit	Department of Electri	cal Power Engi	neering -> Fac	ulty of Electrica	al and C	Control E	Engineering	
Name and surname	Subject supervisor		prof. dr hab. inż. Stanisław Czapp					
of lecturer (lecturers)	Teachers							
Lesson types and methods of instruction	Lesson type	Lecture	Tutorial	Laboratory	Projec	t	Seminar	SUM
	Number of study hours	30.0	0.0	15.0	0.0		0.0	45
	E-learning hours included: 0.0							
Learning activity and number of study hours	Learning activity	Participation in classes includ plan		Participation in consultation hours		Self-study		SUM
	Number of study hours	er of study 45		7.0		48.0		100
Subject objectives	To achieve ability of designing and maintenance of electrical devices in the field of electrical safety							
Learning outcomes	Course outcome		Subject outcome			Method of verification		
	electrical equipment, ways to reduce these hazards, basic principles of health and safety at		current on human beings.			[SW3] Assessment of knowledge contained in written work and projects		
	[K6_U06] has the preparation necessary to work in an industrial environment, applies the principles of occupational health and safety					[SU1] Assessment of task fulfilment		
	[K6_K04] can react in abnormal and emergency situations, threats to health and life when using automation and robotics components and systems in hydrogen devices and installations					[SK5] Assessment of ability to solve problems that arise in practice		
Subject contents	Electrical safety. Health and safety management systems. Occupational risk assessment. Electric shocks. Effects of current on human beings and livestock, threshold of perception, of let-go, of ventricular fibrillation. Electrical impedance of the human body. Touch voltage and body current. Earthing. Earth electrodes, soil resistivity, earthing resistance and their measurement. Earthing resistance calculation. Protection in low voltage installations. Basic protection. Insulation resistance, leakage currents. Protection in case of fault, additional protection. Calculation and testing. Protection in high voltage installations. Earth fault current calculation. Reduction factors related to earth wires and metal sheats. Earthing system for HV installations. Measuring touch voltages. Other hazards. Sources of hazards and protection. Work ergonomics and hygiene. LABORATORY Laboratory model for and wall testing. Effectiveness of protection against electric shock. Earthing in LV systems. Conductivity of floor and wall testing. Effectiveness of protection against electric measurement. Insulation resistance measurement. Earthing electrode resistance measurement. Conductivity of soil measurement. Insulation resistance measurement. Earthing electrode resistance measurement. Electrical devices							
Prerequisites and co-requisites								

Assessment methods	Subject passing criteria	Passing threshold	Percentage of the final grade				
and criteria	Written exam	50.0%	67.0%				
	Practical exercise	100.0%	33.0%				
Recommended reading	Basic literature	Czapp S.: Ochrona przeciwporażeniowa w sieciach i instalacjach niskiego napięcia. PWN, Warszawa 2023					
	Markiewicz H.: Bezpieczeństwo w elektroenergetyce. PWN, Wł Warszawa 2017.						
	Supplementary literature	Musiał E.: Instalacje i urządzenia elektroenergetyczne, WSP, Warszawa 2008.					
	eResources addresses	Adresy na platformie eNauczanie:					
Example issues/ example questions/ tasks being completed	1. Threshold of let-go for 50 Hz sinu	isoidal current is:					
	a) 1 mA						
	b) 10 mA						
	c) 30 mA						
	2. A-type residual current devices detect:						
	a) alternating earth fault current and pulsating direct earth fault current						
	b) only alternating earth fault current						
	c) only pulsating direct earth fault current						
	3. Permissible earth potential rise for long duration of current flow in 110/15 kV substation is:						
	a) 80 V						
	b) 160 V						
	c) 50 V						
Work placement	Not applicable						