

## Subject card

Subject name and code	Safety in the use of electrical equipment, PG_00058363								
Field of study	Hydrogen Technologies and Electromobility								
Date of commencement of studies	October 2024		Academic year of realisation of subject			2027/2028			
Education level	first-cycle studies		Subject group			Obligatory subject group in the field of study			
						Subject group related to scientific research in the field of study			
Mode of study	Full-time studies		Mode of delivery			at the university			
Year of study	4		Language of instruction			Polish			
Semester of study	7		ECTS credits			4.0			
Learning profile	general academic profile		Assessment form			assessment			
Conducting unit	Department of Electrical Power Engineering -> Faculty of Electrical and Control Engineering								
Name and surname	Subject supervisor		prof. dr hab. inż. Stanisław Czapp						
of lecturer (lecturers)	Teachers								
Lesson types and methods of instruction	Lesson type	Lecture	Tutorial	Laboratory	Projec	t	Seminar	SUM	
	Number of study hours	30.0	0.0	15.0	0.0		0.0	45	
	E-learning hours included: 0.0								
Learning activity and number of study hours	Learning activity Participation ir classes include plan			Participation in consultation hours		Self-study		SUM	
	Number of study 45 hours			7.0		48.0		100	
Subject objectives	To achieve ability of designing and maintenance of electrical devices in the field of electrical safety								
Learning outcomes	Course out	come	Subject outcome			Method of verification			
	electrical equipment, ways to reduce these hazards, basic principles of health and safety at		current on human beings.			[SW3] Assessment of knowledge contained in written work and projects			
	[K6_U06] has the preparation necessary to work in an industrial environment, applies the principles of occupational health and safety					[SU1] Assessment of task fulfilment			
	[K6_K04] can react in abnormal and emergency situations, threats to health and life when using automation and robotics components and systems in hydrogen devices and installations		The student knows the principles of applying the protection devices and rescue of people.			[SK5] Assessment of ability to solve problems that arise in practice			
Subject contents  Prerequisites	Electrical safety. Health and safety management systems. Occupational risk assessment. Electric shocks. Effects of current on human beings and livestock, threshold of perception, of let-go, of ventricular fibrillation. Electrical impedance of the human body. Touch voltage and body current. Earthing. Earth electrodes, soil resistivity, earthing resistance and their measurement. Earthing resistance calculation. Protection in low voltage installations. Basic protection. Insulation resistance, leakage currents. Protection in case of fault, additional protection. Calculation and testing. Protection in high voltage installations. Earth fault current calculation. Reduction factors related to earth wires and metal sheats. Earthing system for HV installations. Measuring touch voltages. Other hazards. Sources of hazards and protection. Work ergonomics and hygiene. LABORATORY Laboratory model for demonstration of means of protection against electric shock. Earthing in LV systems. Conductivity of floor and wall testing. Effectiveness of protection against electric shock testing in installations with RCDs. Earth loop impedance measurement. Earthing electrode resistance measurement. Conductivity of soil measurement. Insulation resistance measurement.								
and co-requisites									

Data wygenerowania: 22.11.2024 03:11 Strona 1 z 2

Assessment methods	Subject passing criteria	Passing threshold	Percentage of the final grade				
and criteria	Written exam	50.0%	67.0%				
	Practical exercise	100.0%	33.0%				
Recommended reading	Basic literature Czapp S.: Ochrona przeciwporażeniowa w sieciach i instalacjach niskiego napięcia. PWN, Warszawa 2023						
	Markiewicz H.: Bezpieczeństwo w elektroenergetyce. PWN, WNT, Warszawa 2017.						
	Supplementary literature	Musiał E.: Instalacje i urządzenia elektroenergetyczne, WSP, Warszawa 2008.					
	eResources addresses	Adresy na platformie eNauczanie:					
Example issues/ example questions/ tasks being completed	1. Threshold of let-go for 50 Hz sinu	soidal current is:					
	a) 1 mA						
	b) 10 mA						
	c) 30 mA						
	A-type residual current devices detect:						
	a) alternating earth fault current and pulsating direct earth fault current						
	b) only alternating earth fault current						
	c) only pulsating direct earth fault current						
	3. Permissible earth potential rise for long duration of current flow in 110/15 kV substation is:						
	a) 80 V						
	b) 160 V						
	c) 50 V						
Work placement	Not applicable						

Document generated electronically. Does not require a seal or signature.

Data wygenerowania: 22.11.2024 03:11 Strona 2 z 2